



Certificate of Compliance

Certificate: 1289184

Master Contract: 168390 (111137_0_000)

Project: 70105856

Date Issued: 2017-03-30

Issued to: Carlo Gavazzi Controls S.p.A.
Via Safforze 8
Belluno, 32100
ITALY

The products listed below are eligible to bear the CSA Mark shown



Issued by: Steven Montminy
Steven Montminy

PRODUCTS

CLASS - C321107 - INDUSTRIAL CONTROL EQUIPMENT-Miscellaneous Apparatus

Electronic - magnetically operated timer and multi-function timer relays, component, Cat. No. D or P followed by AA01 or MB01 or AC01 or CB01 or BB01 or BA02 or BB02 or MC01 followed by C or D. Rating input max. 240Vac, 240Vdc; output 8 Amp, 250Vac, 1/2 HP at 240Vac.

Note: May be followed by suffixes.

APPLICABLE REQUIREMENTS

CSA C22.2, No. 14-13 - Industrial Control Equipment.



Supplement to Certificate of Compliance

Certificate: 1289184

Master Contract: 168390 (111137_0_000)

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70105856	2017-03-30	Update of report 1289184 to cover addition of alternate material plastic, alternate construction for terminal block of relay, and an alternate relay model, to the requirement of CSA C22.2 No. 14-13.
2038634	2008-05-20	Addition of alternate certified relay model RT424F05.
1759628	2006-06-21	Addition of model DBA02, alternative construction of DMB01.
1576384	2004-07-21	Alternate construction.
History		
1450000	2003-07-24	Addition of 2 low Voltage, current balancing transistor, models XAA01DM24, XMB01DM24
1418281	2003-04-07	Models DAC01,PAC01,DBB01,PB001,DBB02,PBB02,DCB02,DCB01,PCB01,DMC01,PMC01
1289184	2002-02-08	Models, DAA01,PAA01,DMB01,PMB01